

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

DIRHAM HOME INSULATION CONTRACTING LLC
P.O. Box 11028, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL16020389
Valid Until: 21/10/2021



Current Issue Date: 22/10/2020
Original Issue Date: 23/08/2016



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL16020389

Certificate Issued To:	DIRHAM HOME INSULATION CONTRACTING LLC P.O. Box 11028, Dubai, UAE
Applicable Standard Specification:	EN 14315-1:2013 – Thermal insulating products for buildings – In situ formed sprayed polyurethane (PUR) and Polyisocyanurate (PIR) foam products – Part 1: Specification for the rigid foam spray system before installation
Applicable Specific Rules:	DM-DCLD-RD-DP21-2187 (IC) - Specific Rules for Certification of In-situ Spray-applied polyurethane (PUR) foam Thermal Insulation as per BS EN 14315-1:2013

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	In-Situ Formed Sprayed Polyurethane (PUR) Foam Products CFC Free (<i>see note 2</i>)	DIRHAM	In-Situ Formed Sprayed Polyurethane (PUR) Foam Core Density = 40 Kg/m ³ (min) Min. Thickness = 40 mm k-value: 0.024 W/(K·m) @ 35°C & 60% RH With a minimum Compressive Strength of 100 kPa Product Code: PU EN14315-1-DS(TH)2-CS(10/Y)100-MU(25)

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: CFC Free as per declaration from the company, in compliance with 2017 Al Sa'fat Dubai Green Building Evaluation System.

Original Issue Date : 23 August 2016
Current Issue Date : 22 October 2020
Valid Until : 21 October 2021



ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department